

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7300-1157:122 Page 1 of 1

**CATEGORY:** Misc. Devices/Control Unit Accessories

**LISTEE:** Digital Monitoring Products, 2500 N. Partnership Blvd., Springfield MO 65803  
Contact: Terry Shelton (417) 831-9362 FAX (417) 831-1325

**DESIGN:** Model SLRLX addressable two-wire smoke detector base. Intended for use with separately listed Models SLR-835 and SLR-835H (CSFM Listing No. 7272-0410:107) photoelectric smoke or heat detector heads. This base is intended to be connected to separately listed Models XR200, and XR2400F (CSFM Listed No. 7165-1157:105) or XR500 and XR500N (CSFM Listing No. 7165-1157:123) fire alarm control units. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 24 V dc

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. Intended for vertical wall surfaces and the ceiling.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as a smoke detector base for use with separately listed photoelectric smoke or heat detector heads when used in conjunction with compatible fire alarm control units. Refer to listee's Installation Instructions Manual for details.

06-03-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 3, 2004**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**